		Rotary Compressor: Fixed Sp MODEL DATA - FOR COMPRES			7
			SED AIK		_
1	Manufacturer:	Sullivan Palatek			
	Model Number:	SP11-L30	Date:	2/1/2024	
2	X Air-cooled	Water-cooled	Type:	Screw	
			# of Stages:	1	
3*	Rated Capacity at Full Lo	ad Operating Pressure ^{a, e}	145.0	acfm ^{a,e}	
4*	Full Load Operating Pres	b sure	100	psig ^b	
5	Maximum Full Flow Ope		100	psig ^c	-
	Drive Motor Nominal Ra			_	-
6	Drive Motor Nominal Eff	•	30	hp	_
7			93.6	percent	_
8	Fan Motor Nominal Rating (if applicable)		1.0	hp	_
9	Fan Motor Nominal Efficiency		85.5	percent	_
10*	Total Package Input Pow		9.2	kW ^e	
11	U	Fotal Package Input Power at Rated Capacity and Full Load Operating Pressure ^d		kW^d	
	1 0	t Rated Capacity and Full Load Operating	28.6		_
12*	Pressure ^e		19.72	kW/100 cfm ^e	
13	Isentropic Efficiency		67.38	Percent	
		Performance Verification Program, these items are sipants in the third party verification program:	www.cagi.org	dministrator.	
NOTES	ISO 1217, Annex C; b. The operating pressu	harge terminal point of the compressor package in accor ACFM is actual cubic feet per minute at inlet conditions re at which the Capacity (Item 3) and Electrical Consum	i.	1	
AGI	d. Total package input e. Tolerance is specifie	ttainable at full flow, usually the unload pressure setting tainable before capacity control begins. May require ad ower at other than reported operating points will vary w d in ISO 1217, Annex C, as shown in table below:	ditional power. vith control strategy.		
ed Air & Gas Institute		ower" and "energy" are synonymous for purposes of the Volume Flow Rate		Specific Energy	No Load / Ze
		at specified conditions	Volume Flow Rate	Consumption	Powe
Iember	<u>m³ / min</u>	ft^3 / min	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10
	1.5 to 15	53 to 529.7 Above 529.7	+/- 5	+/- 6	