COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable


Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR			
1	Manufacturer: Sullivan Palatek		
	Model Number: SPM-7.5 1PH	Date:	12/2/2024
2	X Air-cooled Water-cooled	Type:	Screw
	X Oil-injected Oil-free	# of Stages:	1
	Rated Capacity at Full Load Operating Pressure		
3*	a, e	27.2	acfm ^{a,e}
4	Full Load Operating Pressure b	125	psig b
5	Maximum Full Flow Operating Pressure c	125	psig c
6	Drive Motor Nominal Rating	7.5	hp
7	Drive Motor Nominal Efficiency	84	percent
8	Fan Motor Nominal Rating (if applicable)	0.2	hp
9	Fan Motor Nominal Efficiency	75.0	percent
10*	Total Package Input Power at Zero Flow	2.6	kW ^e
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	7.3	kW^d
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure ^e	26.98	kW/100 cfm ^e

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the
 maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document





Member

ROT 030.2

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org