COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR									
1	Manufacturer:	Sulliv	an Palatek						
	Model Number	:: SP25-	L250VFD		Date:	12/06/24			
2	X Air-co	ooled	Water-cooled		Туре:	Screw			
					# of Stages:	1			
3*	Full Load Operating Pressure			100	psig b				
4	Drive Motor Nominal Rating			250	hp				
5	Drive Motor Nominal Efficiency			96.2	percent				
6	Fan Motor Nominal Rating (if applicable)			7.5	hp				
7	Fan Motor Nominal Efficiency			91.0	percent				
	Input Power (kW)			Capacity (acfm) ^{a,d}		Specific Power kW/100 acfm) ^d			
	236.4			1267.7		18.65			
8*	182.0			1014.7		17.94			
	156.3			887.7		17.61			
	109.8			633.6		17.33			
	88.3		,	508.0		17.38			
9*	Total Package Input Power at Zero Flow c, d			0.0	kW				
10	Isentropic Efficiency			74.7%	%				
11	ker FM)	25.00							
	Specific Power (RW/100 ACFM)	15.00	200.0 400.0	600.0 800.0	1000.0	1200.0 1400.0			
			Note: Graph is only a vi Note: Y-Axis Scale, 10 to 35,	Capacity (ACFM) sual representation of the data in + 5kW/100acfm increments if nece 0 to 25% over maximum capacity	Section 8				

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.