COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

				ODEL DATA - FO				
1	Manuf	Manufacturer: Sullivan Palatek						
2	Model	l Number	: SP2	5-250VFD		Date:	11/25/24	
	X Air-cooled Water-cooled				Type:	Screw		
						# of Stages:	1	
3*	Full L	Full Load Operating Pressure			125	psig ^b		
4		Drive Motor Nominal Rating			250		hp	
5	Drive	Drive Motor Nominal Efficiency			96.2		percent	
6	Fan M	Fan Motor Nominal Rating (if applicable)			7.5		hp	
7	Fan M	Motor Nominal Efficiency			91.0	percent		
8*	Input Power (kW)				Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d		
	227.6				1129.1		20.16	
		177.7		-	903.6		19.67	
		154.0			789.7	19.50		
		109.8			564.3	19.46		
		88.9		c, d	452.4		19.65	
9*		Total Package Input Power at Zero Flow			0.0 76.2%	<u>kW</u>		
11 *For mode		25.00 20.00 20.00 20.00 15.00						
			10.00		50.0 600.0 750.0 Capacity (ACFM)	900.0 10	050.0 1200.0	
	Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity els that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrate							
	CAGI websi a. 1 b. c. 1 d.	te for a list Measured a ACFM is ad The operati No Load Po manufactur Tolerance is	t of particip t the dischar ctual cubic f ng pressure ower. In acc er may state s specified in	retriniance verification i r ants in the third party ver ge terminal point of the con eet per minute at inlet condi at which the Capacity (Item ordance with ISO 1217, An "not significant" or "0" on n ISO 1217, Annex E, as sh ver" and "energy" are synon	ification program: npressor package in accorditions. 8) and Electrical Consum nex E, if measurement of in the test report. own in table below:	www.cagi.org	17, Annex E; e measured for this data	
	V	olume Flow	Rate		Specific Energy	Zero Flow		
		plume Flow		Volume Flow Rate %	Specific Energy Consumption %			

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

+/- 8

+/- 7

+/- 6

+/- 5

+/- 10%

+/- 7

+/- 6

+/- 5

+/- 4

ROT 031.1

Below

0.5 0.5 to 1.5

1.5 to 15

Above 15

Below 17.6

17.6 to 53

53 to 529.7

Above 529.7